

Nr 230-02/06

# SERTIFIKAAT

## CERTIFICATE



### Product

External thermal insulation composite system **SKALA WTM with silicate rendering Skala TW.**

### Manufacturer

**SKALA S.p.zo.o.** (Reg no KRS:0000131781), ul. Przemyslowa 60, 43-100 Tychy, POLAND.

### Authorized dealer

**PALAMAR GRUPP OÜ** (Reg no 10977836), Sõle 67, 10312 Tallinn, ESTONIA.

### Product description

- 1) Adhesive: SKALA KW or SKALA KWZ;
- 2) Insulation: Mineral wool;
- 3) Glass fiber mesh: ST 2924-100 AT-15-4256-/2000 or AKE 165A;
- 4) Base coat: SKALA KW;
- 5) Key coat: SKALA POW;
- 6) Finishing plaster: SKALA TW.

### Classification standard

EVS-EN 13501-1:2004 "Fire classification of construction products and building elements. Part 1: Classification using test data from reaction to fire tests".

### Classification

Based on test results (EN 13823:2002 and EN ISO 11925-2) **SKALA WTM with silicate rendering Skala TW** meets the reaction to fire class:

**B-s1, d0.**

### Basis

1. Assessment report No RV-15-2006;
2. Decision of the Board No 12/03/06, 9.03.2006.a.

### Associated documents

1. Quality inspections register R3.

### Quality control

Quality control is carried out according to quality supervision contract no KJL-90/2006.

### Certificate validity conditions

Present certificate is valid from 09.03.2006 till 08.03.2009 on condition that regular manufacturing instruction supervision is performed in due time and according note is made in register. Current certificate is not certificate of conformity according to the building directive 89/106/EEC, and don't give authority to place CE-sign to the product.



Janek Neltras

Chief executive



PC 015 (EN 45011)  
I 032 (EN 45004)

Sertifitseerimisbüro EstCert OÜ  
Reg nr 10952693  
Laki 14a - 610, 10621 Tallinn

Tel: 651 7797  
Faks: 651 7796  
e-post: info@estcert.ee